



No Lesen : PU012503

Licence No :

LESEN PENSIJILAN BARANGAN *Product Certification Licence*



**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
*SIRIM QAS International Sdn. Bhd. hereby grants to***

**UTAMA CABLES SDN. BHD.
JA 955, PLOT 5C-D
KAWASAN PERINDUSTRIAN MERLIMAU
77300 MERLIMAU
MELAKA, MALAYSIA**

**Lesen untuk menggunakan Tanda Pensijilan di atas barangan
*a licence to use the Certification Mark on***

POWER CABLES WITH EXTRUDED SOLID INSULATION

Please refer to detail in the SCHEDULE

**sebagai mematuhi keperluan
*as complying with***

IEC 60502-1 : 2004

Ts. Md. Adha bin Katni @ Rahmat
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SIRIM QAS International Sdn. Bhd.
(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

<https://www.sirim-qas.com.my>
<https://www.malysiancertified.com.my>

Tarikh Mula Pensijilan : 30 December 2004

Certified Since

Sah Sehingga : 30 December 2026

Valid Until

Tarikh Dikeluarkan : 01 January 2026

Issue Date

No Siri : 121812

Serial No

Lesen ini dianugerahkan tertakuk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

SCHEDULE

UTAMA CABLES SDN. BHD.



SIRIM

Trade Mark	: UTAMA
Model	: XLPE INSULATED PVC SHEATHED, NON-ARMOURED, SHAPED STRANDED PLAIN ANNEALED COPPER CONDUCTOR 2-CORE, 3-CORE, 4-CORE (1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500)MM ²
Rating	: 600/1000V
Trade Mark	: UTAMA
Model	: XLPE INSULATED PVC SHEATHED, NON-ARMOURED, STRANDED CIRCULAR COMPACTED PLAIN ALUMINIUM CONDUCTOR SINGLE CORE (16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630, 800, 1000)MM ²
Rating	: 600/1000V
Trade Mark	: UTAMA
Model	: XLPE INSULATED PVC SHEATHED, ARMOURED, SHAPED STRANDED PLAIN ALUMINIUM CONDUCTOR 1-CORE, 2-CORE, 3-CORE, 4-CORE (16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630)MM ²
Rating	: 600/1000V
TEST REPORT 2024EA0688 (STANDARD IEC 60502-1 : 2009) & 2020EA0220 (STANDARD IEC 60502-1 : 2009)	
Trade Mark	: UTAMA
Model	: XLPE INSULATED PVC SHEATHED, ARMOURED MULTICORE, AUXILIARY STRANDED COPPER CONDUCTOR 7, 12, 19, 27, 37, 48-CORE (1.5, 2.5, 4)MM ²
Rating	: 600/1000V
Trade Mark	: UTAMA
Model	: XLPE INSULATED PVC SHEATHED ARMOURED, STRANDED CIRCULAR COMPACTED PLAIN ANNEALED COPPER CONDUCTOR SINGLE CORE (16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630)MM ²
Rating	: 600/1000V
Trade Mark	: UTAMA
Model	: XLPE INSULATED PVC SHEATHED, ARMOURED, SHAPED STRANDED PLAIN ANNEALED COPPER CONDUCTOR 2-CORE, 3-CORE, 4-CORE (1.5, 2.5, 4, 6, 10, 16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500)MM ²
Rating	: 600/1000V
Trade Mark	: UTAMA
Model	: XLPE INSULATED PVC SHEATHED, NON-ARMOURED, STRANDED CIRCULAR COMPACTED PLAIN ANNEALED COPPER CONDUCTOR SINGLE CORE (16, 25, 35, 50, 70, 95, 120, 150, 185, 240, 300, 400, 500, 630, 800, 1000)MM ²
Rating	: 600/1000V

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

<https://www.sirim-qas.com.my>
<https://www.malysiancertified.com.my>

Tarikh Mula Pensijilan : 30 December 2004

Certified Since

Sah Sehingga : 30 December 2026

Valid Until

Tarikh Dikeluarkan : 01 January 2026

Issue Date

No Siri : 121812

Serial No

Lesen ini dianugerahkan tertakuk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

SCHEDULE

UTAMA CABLES SDN. BHD.



Trade Mark : UTAMA
Model : PVC INSULATED, PVC SHEATHED, ARMOURED AUXILIARY CABLES WITH
CIRCULAR STRANDED COPPER CONDUCTOR, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14,
15, 16, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30 ~ 48-CORE (1.5, 2.5)MM²
Rating : 600/1000V
TEST REPORT 2024EA0430 & 2024EA0430 (STANDARD IEC 60502-1 : 2021)

End of page

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

<https://www.sirim-qas.com.my>
<https://www.malysiancertified.com.my>

Tarikh Mula Pensijilan : 30 December 2004

Certified Since

Sah Sehingga : 30 December 2026

Valid Until

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

Tarikh Dikeluarkan : 01 January 2026

Issue Date

No Siri : 121812

Serial No